


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:120.70V I:0.2638A P:28.997W PF:0.9105 Freq:59.98Hz Lamp Flux:1966.19x1 lm		
NAME: LB76352	TYPE:	WEIGHT:
SPEC.: 2700K	DIM.:	SERIAL No.:
MFR.: LB	SUR.:	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA				Eff: 67.81 lm/W
MODEL	LB76352	I _{max} (cd/klm)	347.8	S/MH (C0/180)	1.28	
NOMINAL POWER (W)	30	LOR (%)	100.0	S/MH (C90/270)	1.28	
RATED VOLTAGE (V)	120.0	TOTAL FLUX (lm/klm)	1000.0	η UP, DN (C0-180)	0.0,49.8	
NOMINAL FLUX (lm)	1966.19	CIE CLASS	DIRECT	η UP, DN (C180-360)	0.0,50.2	
LAMPS INSIDE	1	η up (%)	0.0	CIBSE SHR NOM	1.25	
TEST VOLTAGE (V)	120	η down (%)	100.0	CIBSE SHR MAX	1.35	

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT: lx/klm)



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3 °C
Operators:
Test Date: 2024-03-15

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System: EVERFINE GO-2000B_V1 SYSTEM V2.00.479
Humidity: 65.0%
Test Distance: 10.000m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:


γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum, lamp
10	342.3	336.4	332.9	330.7	342.5	337.0	333.8	331.5	0- 10	32.24	32.24	3.22,3.22
20	325.8	319.7	316.3	314.5	326.2	320.9	317.8	316.0	10- 20	92.67	124.9	12.5,12.5
30	298.5	292.5	289.2	288.0	299.2	294.2	291.4	290.0	20- 30	141.4	266.3	26.6,26.6
40	260.7	255.0	252.0	251.6	261.5	256.9	254.6	253.8	30- 40	171.9	438.2	43.8,43.8
50	213.1	207.8	205.3	205.5	214.6	210.5	208.2	208.5	40- 50	179.6	617.8	61.8,61.8
60	158.0	153.4	151.6	152.5	159.4	156.0	154.6	155.0	50- 60	162.9	780.7	78.1,78.1
70	99.77	95.74	94.64	96.26	100.9	97.89	97.04	98.24	60- 70	124.7	905.4	90.5,90.5
80	44.02	41.26	40.73	42.35	44.57	42.40	42.13	43.64	70- 80	73.13	978.6	97.9,97.9
90	0.8651	0.8298	0.8757	0.8440	0.6745	0.6745	0.8192	0.7627	80- 90	21.43	1000	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd/klm									UNIT:lm/klm		

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:
Test Date:2024-03-15

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.00.479
Humidity:65.0%
Test Distance:10.000m [K=1.0000]
Remarks:

LUMINANCE LIMITATION CURVES

Test:U:120.70V I:0.2638A P:28.997W PF:0.9105 Freq:59.98Hz Lamp Flux:1966.19x1 lm		
NAME: LB76352	TYPE:	WEIGHT:
SPEC.: 2700K	DIM.:	SERIAL No.:
MFR.: LB	SUR.:	Shielding Angle:



LUMINANCE cd/(m2)		
G (DEG)	C0/180	C90/270
85	3993	3630
80	4485	4150
75	4856	4559
70	5162	4897
65	5397	5154
60	5593	5366
55	5748	5528
50	5866	5651
45	5958	5750


C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:
Test Date:2024-03-15

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.00.479
Humidity:65.0%
Test Distance:10.000m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:120.70V I:0.2638A P:28.997W PF:0.9105 Freq:59.98Hz Lamp Flux:1966.19x1 lm		
NAME: LB76352	TYPE:	WEIGHT:
SPEC.: 2700K	DIM.:	SERIAL No.:
MFR.: LB	SUR.:	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0
p _w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
p _{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio															



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:
Test Date:2024-03-15

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.00.479
Humidity:65.0%
Test Distance:10.000m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:120.70V I:0.2638A P:28.997W PF:0.9105 Freq:59.98Hz Lamp Flux:1966.19x1 lm		
NAME: LB76352	TYPE:	WEIGHT:
SPEC.: 2700K	DIM.:	SERIAL No.:
MFR.: LB	SUR.:	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)										
0.0																	
1.0	.315	.179	.057	.308	.176	.056	.294	.169	.054	.282	.163	.052	.271	.157	.051		
2.0	.295	.162	.050	.289	.159	.049	.277	.154	.048	.266	.149	.047	.256	.145	.046		
3.0	.273	.145	.043	.267	.143	.043	.257	.139	.042	.247	.135	.042	.238	.132	.041		
4.0	.251	.131	.038	.246	.129	.038	.237	.126	.038	.229	.123	.037	.221	.120	.037		
5.0	.232	.118	.034	.228	.117	.034	.220	.114	.034	.212	.112	.033	.205	.109	.033		
6.0	.215	.108	.031	.211	.107	.031	.204	.105	.030	.197	.102	.030	.191	.100	.030		
7.0	.200	.099	.028	.197	.098	.028	.190	.096	.028	.184	.094	.027	.178	.093	.027		
8.0	.187	.091	.026	.184	.090	.026	.178	.089	.025	.172	.087	.025	.167	.086	.025		
9.0	.175	.085	.024	.172	.084	.024	.167	.083	.023	.162	.081	.023	.157	.080	.023		
10.0	.164	.079	.022	.162	.078	.022	.157	.077	.022	.153	.076	.022	.149	.075	.021		

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients (CCEC)										
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020		
1.0	.181	.156	.134	.155	.134	.115	.106	.092	.080	.061	.053	.046	.019	.017	.015		
2.0	.173	.132	.098	.148	.114	.084	.101	.079	.059	.058	.046	.034	.019	.015	.011		
3.0	.165	.114	.074	.141	.099	.064	.097	.069	.045	.056	.040	.026	.018	.013	.009		
4.0	.157	.101	.058	.135	.087	.050	.093	.061	.035	.054	.036	.021	.017	.012	.007		
5.0	.150	.091	.047	.129	.078	.041	.089	.055	.029	.051	.032	.017	.017	.010	.006		
6.0	.143	.082	.039	.123	.071	.034	.085	.050	.024	.049	.029	.014	.016	.010	.005		
7.0	.136	.075	.033	.117	.065	.029	.081	.046	.020	.047	.027	.012	.015	.009	.004		
8.0	.129	.070	.029	.111	.060	.025	.077	.042	.018	.045	.025	.011	.015	.008	.003		
9.0	.123	.065	.025	.106	.056	.022	.074	.039	.016	.043	.023	.009	.014	.008	.003		
10.0	.118	.060	.022	.101	.052	.019	.070	.037	.014	.041	.022	.008	.013	.007	.003		

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:
Test Date:2024-03-15

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.00.479
Humidity:65.0%
Test Distance:10.000m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:120.70V I:0.2638A P:28.997W PF:0.9105 Freq:59.98Hz Lamp Flux:1966.19x1 lm										
NAME: LB76352					TYPE:			WEIGHT:		
SPEC.: 2700K					DIM.:			SERIAL No.:		
MFR.: LB					SUR.:			Shielding Angle:		
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	16.6	18.2	16.9	18.4	18.6	16.5	18.0	16.7	18.2	18.4
3H	18.2	19.6	18.5	19.8	20.1	18.0	19.4	18.3	19.6	19.9
4H	18.8	20.2	19.1	20.4	20.7	18.6	19.9	18.9	20.2	20.4
6H	19.3	20.6	19.6	20.8	21.1	19.0	20.3	19.4	20.6	20.9
8H	19.5	20.7	19.8	21.0	21.3	19.2	20.4	19.5	20.7	21.0
12H	19.6	20.7	19.9	21.0	21.3	19.3	20.4	19.6	20.7	21.0
4H 2H	17.2	18.6	17.5	18.8	19.1	17.1	18.4	17.4	18.7	19.0
3H	19.0	20.1	19.3	20.4	20.7	18.8	20.0	19.1	20.3	20.6
4H	19.7	20.8	20.1	21.1	21.5	19.5	20.6	19.9	20.9	21.3
6H	20.3	21.3	20.7	21.6	22.0	20.1	21.1	20.5	21.4	21.8
8H	20.5	21.4	21.0	21.8	22.2	20.3	21.2	20.7	21.6	21.9
12H	20.7	21.5	21.1	21.9	22.3	20.4	21.3	20.9	21.6	22.0
8H 4H	20.0	20.9	20.4	21.2	21.6	19.8	20.7	20.2	21.1	21.5
6H	20.7	21.5	21.2	21.9	22.3	20.5	21.3	21.0	21.7	22.1
8H	21.0	21.7	21.5	22.1	22.6	20.8	21.5	21.3	21.9	22.4
12H	21.3	21.9	21.8	22.3	22.8	21.0	21.6	21.5	22.0	22.5
12H 4H	20.0	20.8	20.4	21.2	21.6	19.8	20.6	20.2	21.0	21.4
6H	20.8	21.5	21.3	21.9	22.3	20.6	21.3	21.0	21.7	22.1
8H	21.1	21.7	21.6	22.2	22.6	20.9	21.5	21.4	21.9	22.4
Variations with the observer position at spacings(CIE Pub.117):										
S = 1.0H	+ 0.1 / - 0.2					+ 0.2 / - 0.2				
1.5H	+ 0.2 / - 0.3					+ 0.2 / - 0.3				
2.0H	+ 0.2 / - 0.3					+ 0.2 / - 0.3				

CIE Pub.117, 1966 lm Total Lamp Luminous Flux Correct ($8\log(F/F_0) = 2.3$)
Area: 0.111111 m²

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:
Test Date:2024-03-15

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.00.479
Humidity:65.0%
Test Distance:10.000m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:120.70V I:0.2638A P:28.997W PF:0.9105 Freq:59.98Hz Lamp Flux:1966.19x1 lm		
NAME: LB76352	TYPE:	WEIGHT:
SPEC.: 2700K	DIM.:	SERIAL No.:
MFR.: LB	SUR.:	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	57	45	38	56	45	38	55	45	38	32
0.80	67	55	48	66	55	48	64	54	47	40
1.00	76	64	57	74	64	57	72	65	56	49
1.25	83	72	65	81	71	64	78	70	64	56
1.50	88	78	71	86	77	70	83	75	69	61
2.00	95	86	79	93	85	79	89	82	77	69
2.50	99	91	85	96	89	84	93	87	82	73
3.00	102	95	89	100	93	88	96	90	86	78
4.00	106	100	95	104	98	94	99	95	91	82
5.00	108	104	99	106	102	98	101	98	95	86
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.3°C
 Operators:
 Test Date: 2024-03-15

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
 Test System: EVERFINE GO-2000B_V1 SYSTEM V2.00.479
 Humidity: 65.0%
 Test Distance: 10.000m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

Test:U:120.70V I:0.2638A P:28.997W PF:0.9105 Freq:59.98Hz Lamp Flux:1966.19x1 lm		
NAME: LB76352	TYPE:	WEIGHT:
SPEC.: 2700K	DIM.:	SERIAL No.:
MFR.: LB	SUR.:	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 2024-03-15

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System: EVERFINE GO-2000B_V1 SYSTEM V2.00.479
Humidity: 65.0%
Test Distance: 10.000m [K=1.0000]
Remarks:

AAI Figure

Test:U:120.70V I:0.2638A P:28.997W PF:0.9105 Freq:59.98Hz Lamp Flux:1966.19x1 lm		
NAME: LB76352	TYPE:	WEIGHT:
SPEC.: 2700K	DIM.:	SERIAL No.:
MFR.: LB	SUR.:	Shielding Angle:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:
Test Date:2024-03-15

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.00.479
Humidity:65.0%
Test Distance:10.000m [K=1.0000]
Remarks:

ISOLUX DIAGRAM

Test:U:120.70V I:0.2638A P:28.997W PF:0.9105 Freq:59.98Hz Lamp Flux:1966.19x1 lm		
NAME: LB76352	TYPE:	WEIGHT:
SPEC.: 2700K	DIM.:	SERIAL No.:
MFR.: LB	SUR.:	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 2024-03-15

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System: EVERFINE GO-2000B_V1 SYSTEM V2.00.479
Humidity: 65.0%
Test Distance: 10.000m [K=1.0000]
Remarks:

LED Avg.L Report

Test:U:120.70V I:0.2638A P:28.997W PF:0.9105 Freq:59.98Hz Lamp Flux:1966.19x1 lm		
NAME: LB76352	TYPE:	WEIGHT:
SPEC.: 2700K	DIM.:	SERIAL No.:
MFR.: LB	SUR.:	Shielding Angle:


AvgL	cd/m2
L_0~180 (65) av	5426
L_0~180 (75) av	4887
L_0~180 (85) av	4024
L_90~270 (65) av	5214
L_90~270 (75) av	4629
L_90~270 (85) av	3713
L_45 (65) av	5263
L_45 (75) av	4708
L_45 (85) av	3828

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:
Test Date:2024-03-15

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.00.479
Humidity:65.0%
Test Distance:10.000m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3 °C
Operators:
Test Date: 2024-03-15

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
Test System: EVERFINE GO-2000B_V1 SYSTEM V2.00.479
Humidity: 65.0%
Test Distance: 10.000m [K=1.0000]
Remarks:

Shielding Angle:

UNIT: cd/klm

C:\IES原始文件\LB76352 ADS15R-Tunable-5CCTWH-2700K-2024-3-15.GOS